

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/2022/School/WZ/ 112

Dated: 28/2 / 2022

FIRE SAFETY CERTIFICATE

Certified that the **Laurel Convent School, D-2/56, Budh Vihar, Phase-I, Delhi-110086**, comprised of **Ground floor and 02 upper floor** owned occupied by the **Laurel Convent School** was issued fire safety certificate vide this office letter no. **DFS/MS/2009/1746** dated **11/06/2009**. The premises was re-inspected by the officer and observed that the school have deemed complied with the fire prevention and safety requirements in accordance with requirements of circular issued by **Directorate of Education** letter no. **3298-3398** dated **01.03.2011** and verified by the officer concerned of Fire Service on **21.02.2022** in the presence of **Mrs. Jyoti, Principal** and that the building/premises is fit for occupancy Group B Educational for ground and first floor only with effect from 28/2/22..... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 28/2/22....., at New Delhi.


(Dhrampal Bhardwaj)
Dy. Chief Fire Officer
Tel:-01123414250

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi, Old Sect. Delhi – 54.
2. The Principal, Laurel Convent School, D-2/56, Budh Vihar Phase-I, Delhi-110086

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doiit_fire/FIRE/Home/Forms